

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210882
Address: 202 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, November 09, 2021

Corrective Action Required:

1	Miscellaneous Correction	-B vent too close to water line at water heater -water heater supply line leaking -security screws in back door -address back steps, no rail -address back porch safety guard -splash blocks
---	--------------------------	---

Corrective Action Required:

2	Miscellaneous Correction	-irrigation permit and back flow certification -B vent too close to water line at water heater -water heater supply line leaking -security screws in back door -address back steps, no rail -address back porch safety guard -splash blocks
---	--------------------------	---

Comments: