

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213385
Address: 121 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, November 09, 2021

Corrective Action Required:

1	Miscellaneous Correction	GARAGE PORTAL FRAME ONLY - NAIL STHD14 HOLDDOWNS -
---	--------------------------	---

GARAGE PORTAL FRAME INSPECTIONS WILL BE DONE WITH ALL ROUGH
INSPECTION LEAVE EXPOSED FOR INSPECTION

Comments: