

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212322  
Address: 2906 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Tuesday, November 09, 2021

Informational:

1 Misc

GARAGE PORTAL EXTERIOR OK TO COVER

Corrective Action Required:

2 Misc

-fireblock vertical every 10' between studs and foundation wall/framing at finished basement, seal any penetrations and gaps in fireblock material  
-fireblock between top plates at finished basement

**Comments:**