

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210128
Address: 2365 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, November 09, 2021

Corrective Action Required:

1	Miscellaneous Correction	-gfcı in bathroom by garage will not reset -smoke detectors not working - 1/2 " through bolts or equivalent on deck post -outlet above mantel needs box extension
---	--------------------------	--

Comments: