

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210880
Address: 2118 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|-----------|----------------------------|
| All Rough Inspection - Residential | Michael Harkins | Not Ready | Tuesday, November 09, 2021 |

Corrective Action Required:

| | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | Fire block dead space & chase dining room Fire block furr outs garage Furr out HVAC for insulation (FIRE BLOCKING) Fire block soffit near patio door Fire block chase in pantry Fire block DWV bath 5 (2018 IRC R302.11) Address bores in LVL above refrigerator (DON'T SEE ENGINEER'S LETTER UPLOADED) LETTER DID NOT ADDRESS HVAC BORED THROUGH LVL ABOVE PANTRY DOOR |
|---|--------------------------|--|

Comments: