

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211034  
Address: 318 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Not Ready	Tuesday, November 09, 2021

Corrective Action Required:

1	Miscellaneous Correction	Furr out HVAC ducts garage to allow for insulation ( needs fire blocking when complete )  Fire block HVAC chase at stairway Fire block HVAC chase near patio door ( refer to R302.11 2018 IRC )
---	--------------------------	--

**Comments:**