

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210507
Address: 1717 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Tuesday, November 09, 2021

Corrective Action Required:

1	DCM1 ESC REQUIRED NO FURTHER INSP	-maintain and bring erosion control into compliance, clean all and gravel from street, correct issues before rescheduling reinspection
---	---	--

Comments: