

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212479
Address: 3112 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, November 09, 2021

Informational:

1	Misc	-GARAGE PORTAL EXTERIOR OK TO COVER
---	------	-------------------------------------

Corrective Action Required:

2	Misc	-seal all top plate penetrations - garage -dryer duct over max length -install bedroom windows -CS-PF bracing per plans at dining room windows -Fireblock between top plates at finished basement -Fireblock between studs at bump out top plate basement -Fireblock vertical to horizontal at furred down soffit ends - remove Kraft paper from insulation used as fireblock
---	------	---

Comments: