

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20210263	Date:	November 10, 2021
Project Title:	JOHN KNOX VILLAGE MEADOWS	Applicant:	
	PHASE II - INDEPENDENT LIVING APARTMENTS		
Location:	1801 NW OBRIEN RD, LEES SUMMIT, MO 64081520 NW	JOHNSON CONTROLS FIRE PROTECTION LP	
	HOPE LN, LEES SUMMIT, MO 64081	P O BOX 3042	
Type of Work:		BOCA RATON, FL 33431	
Occupancy Group:	R-2	Primary: (561) 912-6108	Ext: CORP
Description:	NEW SENIOR LIVING APARTMENTS		
	WITH PARKING GARAGE BELOW, ADDITIONAL PARKING		
	AT 1801 NW OBRIEN RD		
	GARAGE CONSTRUCTION TYPE IS IB		
Construction Type:	Type VA (1 hour)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Alarm Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.  
(Informational Purposes)  
Call (816)969-1300 to schedule testing.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**