

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20211560  
Address: 464 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Michael Harkins	Failed	Wednesday, November 10, 2021

Corrective Action Required:

1	Miscellaneous Correction	PROVIDE EXPANSION TANK WATER HEATER PROVIDE GFCI PROTECTION RECEPTACLES AT SINK NEXT TO DRYER PROVIDE CHROME COVER PLATES @ CLEANOUT IN RESTROOMS
---	--------------------------	---

: OK TO STOCK & TRAIN :

**Comments:**