

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214994
Address: 1701 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Wednesday, November 10, 2021

Corrective Action Required:

1	Misc	EROSION CONTROL REQUIRED ON LOT, FOOTING POURED ON 11/8/21, THIRD PARTY REPORT INDICATES THAT EROSION CONTROL IS IN COMPLIANCE, ADDRESS EROSION CONTROL IMMEDIATELY, SPOILS PILES AGAINST CURB LINE- STOP WORK ISSUED
---	------	---

Comments: