

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215563
Address: 1620 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Wednesday, November 10, 2021

Corrective Action Required:

1	Misc	NO EROSION CONTROL PRESENT ON LOT, EROSION CONTROL REQUIRED, ADDRESS EROSION CONTROL IMMEDIATELY, REQUIRED TO BE PRESENT AT LOT FROM EXCAVATION, SPOILS PILES AT REAR OF LOT IN SWALE
---	------	---

Comments: