CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214591

Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Footing Inspection - Michael Harkins Failed Wednesday, November

Commercial 10, 2021

Corrective Action Required:

1 Miscellaneous - PROVIDE 3RD PARTY INSPECTION REPORT WITHIN 48 HOURS OF POUR -

Correction - CITY INSPECTION REQUIRED ON COMMERCIAL FOOTING -

Comments: