

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20212684  
Address: 3206 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Thursday, November 11, 2021

Corrective Action Required:

1	SEC. 7-1403 PREMISES IDENTIFICATION	Approved numbers or addresses shall be provided for all new dwelling unit structures in such a position as to be plainly visible and legible from the street or road fronting the property. Each dwelling unit within a multiple dwelling unit structure shall be identified at the main entry with premises identification unique to each dwelling unit. Residential dwelling units and structures housing multiple dwelling units accessed by private drive(s) or parking lot(s) shall also provide approved numbers or addresses in such a position as to be plainly visible and legible from such drive(s) or parking lot(s). Approved numbers or address characters shall be a minimum height of 4 inches (76 mm) and minimum stroke of 0.5 inches (12.7 mm). Approved numbers or address characters shall be of a contrasting color to the background itself.
---	---	---

Corrective Action Required:

2	Miscellaneous Correction	INSPECTION DENIED  NO FOOTING INSPECTION ON RECORD  NO ADDRESS POSTED  WE WILL NOT PERFORM SEPARATE PORTAL FRAME INSPECTIONS - THESE WILL BE COMPLETED AT THE ALL ROUGH 1ST INSPECTION
---	-----------------------------	--

**Comments:**