

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20210599  
Address: 2051 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Commercial</b>	Michael Harkins	Failed	Thursday, November 11, 2021

Informational:

1	Misc	(7) )LIGHT POLE BASES CAGE W/ DRIVEN GROUND ROD OK TO POUR. - (7) COLUMNS FORMED UP W/ BOLT PLATES -
---	------	---------------------------------------------------------------------------------------------------------

Corrective Action Required:

2	Miscellaneous Correction	PROVIDE CITY STAMPED REVISED PLANS FOR DRIVE THRU & CANOPY PIERS
---	--------------------------	------------------------------------------------------------------

**Comments:**