

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214367
Address: 3110 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, November 11, 2021

Corrective Action Required:

1	Misc	-APPROVED PLANS REQUIRE 8" X 16" FOOTING, SEVERAL AREAS THROUGHOUT FOOTING LESS THAN 8" ON ROCK, HAVE ENGINEER ADDRESS CONDITIONS -PROVIDE SOLID FOOTING FOR GARAGE PIER ON SOIL, SOIL HAS FALLEN BELOW PIER
---	------	---

Comments: