

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20200866
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	Diana Johnson	Passed	Tuesday, October 19, 2021

Informational:

1 Misc

On 10/18/2021 I observed contractor, Randy Spalding Excavation conduct a proof roll. The contractor agreed to excavating and adding rock to strengthen the depressed areas throughout the project site.

On 10/19/2021 I observed the contractor hauling in rock to various areas throughout the project site.

On Thursday, 11-11-2021 I performed a sub-base proof roll for that passed roadway compaction for placement of asphalt base coarse with Spalding Excavating.

Comments: