

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212479
Address: 3112 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, November 11, 2021

Informational:

1	Misc	-GARAGE PORTAL EXTERIOR OK TO COVER
---	------	-------------------------------------

Corrective Action Required:

2	Misc	-install bedroom windows -CS-PF bracing per plans at dining room windows - nailing at exterior sheathing per plans, see IRC 602.10.6.4, min overlap at band rim joist w/ 8D nailing 3" oc at top and bottom of band/rim joist, install tension straps at top plate/header/jack stud per plans/code
---	------	---

****OK TO INSULATE****

Comments: