

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214416
Address: 540 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Fire Line Construction Inspection	John Jackson	Partial	Tuesday, November 09, 2021

Informational:
1 Misc 11/09/21 Tuesday (ESS)
Contractor installed Backflow Preventer Vault.
11/12/21 Friday
Contractor working on the installation of fire line 6" PVC (C-900) as per plan.

Comments: