

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210599
Address: 2051 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Patrick Schonfeldt	Partial	Friday, November 12, 2021

Informational:

1	Misc	(7))LIGHT POLE BASES CAGE W/ DRIVEN GROUND ROD OK TO POUR. - (7) COLUMNS FORMED UP W/ BOLT PLATES - -(8) PIERS AND CAGES FOR DRIVE THRU MENU, CANOPIES AND CLEARANCE BARS
---	------	--

Comments: