

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211772  
Address: 314 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Eric Sharp	Failed	Friday, November 12, 2021

Informational:

1	Misc	Driveway is framed up and has aggregate in place and compacted. Meets LS and ADA specs. 11/3 ES
---	------	---

Corrective Action Required:

2	Misc	Driveway approach is out of tolerance through the 5' sidewalk lane and doesn't meet LS/ADA spec. Need to remove and replace. 11/12 ES
---	------	---

**Comments:**