CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20204752

Address: 2045 NW ASHURST DR, LEES SUMMIT, MO 64081

Inspected On: Friday, November 12, 2021

Inspected By: Shawn Hoffman

Expiration Date: 12/3/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Shawn Hoffman Temporary C of O Friday, November

Codes Residential

12, 2021

Corrective Action Required:

1 Misc outlet on front porch not GFCI

--final grading and sod

--check water meter hight at final grading

--splash blocks