



Proofroll Inspection Report

Alpha Omega Geotech, Inc
1701 State Avenue
Kansas City, KS 66102
Phone: 913-371-0000

Client:
LSPH Investors, LLC
7939 Floyd Street
Overland Park, KS 66204

Project:
21-390F
Chipotle Lee's Summit
1130 SE Oldham Pkwy
Lee's Summit, MO

Activity Date: 10/21/2021

Technician: Welhoff, Tracy

Time In: 10:00

Time Out: 10:30

Temperature (F): 60

Weather: Sunny

GENERAL OBSERVATIONS

Proofroll Observations:

Visual Proofroll Acceptance: Yes

Building pad was proof rolled with a fully loaded tandem axle dump truck.

If Yes, Please Explain: No significant pumping or rutting was observed.

Source Of Fill (If Applicable): N/A

Visual Description Of Subgrade: brown/ reddish brown fat clay

Are There Non-Compliance Items: No