

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215655
Address: 1621 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Patrick Schonfeldt	Failed	Monday, November 15, 2021

Corrective Action Required:

1	Misc	INSPECTION DENIED EROSION CONTROL REQUIRED, EROSION CONTROL NOT IN COMPLIANCE AT TIME OF INSPECTION 9:37 AM
---	------	---

Comments: