## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRRES20210673Address:1619 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, November 12, 2021
Corrective Action Required:			
	-uncover water meter to check		
	-splash blocks and sump pump discharge 36" from foundation		
	-premises identification must comply with security code section 7-1404		
	-deck beams to columns per plan.		

Mitchell Schwarz 11/12/2021 9:08 AM

Comments: