

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210427
Address: 250 NW MCNARY CT, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Michael Harkins	Partial	Tuesday, November 16, 2021

Informational:
1 Misc UNDERGROUND CONDUIT FOR 3 LIGHT POLE BASES (2) EAST (1) SOUTH
DRIVEN GROUND RODS IN PLACE

Comments: