

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210695  
Address: 206 NW JOSHUA DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Tuesday, November 16, 2021

Corrective Action Required:

1	Misc	PROVIDE ACCESS TO BACK YARD FOR INSPECTION
---	------	--

- Sidewalk inspection pending
- Address 6x6 cedar post covered deck not continuous per plan
- Obtain lawn irrigation permit & submit back flow certification }
- Exterior drain tiles shall discharge 36" from foundation
- Repair broken and extend PVC @ sump discharge

**Comments:**