

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211738
Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Tuesday, November 16, 2021

Informational:	
1 Misc	- OSB PARAPET WALLS ROOF SIDE, DENSROCK EXTERIOR WALLS -
Corrective Action Required:	
2 Miscellaneous	Provide mid point support vertical 2" & smaller DWV
Correction	Provide boca plate that extends 2" above & below top & bottom plates where required
	Complete Electrical in loft

Comments: