

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215563  
Address: 1620 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                             | Inspector:         | Outcome:  | Date:                      |
|-----------------------------------------|--------------------|-----------|----------------------------|
| <b>Footing Inspection - Residential</b> | Patrick Schonfeldt | Not Ready | Tuesday, November 16, 2021 |

Corrective Action Required:

|   |      |                   |
|---|------|-------------------|
| 1 | Misc | INSPECTION DENIED |
|---|------|-------------------|

EROSION CONTROL REQUIRED ON LOT AT STREET, PROTECT SWALE ALONG REAR OF LOT, NO EROSION CONTROL AT TIME OF INSPECTION 10:30 AM, EROSION CONTROL WAS FAILED ON 11/10, SEE INSPECTION REPORT

**Comments:**