

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215563  
Address: 1620 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Patrick Schonfeldt	Failed	Tuesday, November 16, 2021

Corrective Action Required:

1	Misc	NO EROSION CONTROL PRESENT ON LOT, EROSION CONTROL REQUIRED, ADDRESS EROSION CONTROL IMMEDIATELY, REQUIRED TO BE PRESENT AT LOT FROM EXCAVATION, SPOILS PILES AT REAR OF LOT IN SWALE
---	------	---

11/16/21 - FOOTING INSPECTION DENIED

EROSION CONTROL REQUIRED ON LOT AT STREET, PROTECT SWALE ALONG REAR OF LOT, NO EROSION CONTROL AT TIME OF INSPECTION 10:30 AM, EROSION CONTROL WAS FAILED ON 11/10, SEE INSPECTION REPORT

**Comments:**