

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214938  
Address: 1519 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Patrick Schonfeldt	Partial	Tuesday, November 16, 2021

Corrective Action Required:

1	Misc	UPLOAD ENGINEER REPORT THAT WAS ON SITE AT INSPECTION CONCERNING SOIL CONDITIONS FOR FOOTING
---	------	--

**Comments:**