

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210348
Address: 2930 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, November 16, 2021

Corrective Action Required:

1	Misc	TCO UNTIL 12/8/21
---	------	-------------------

-Driveway and sidewalk inspection need complete
-siding must be 6" from grade see attached photos
Mitchell Schwarz 11/16/2021 1:46 PM

Comments: