

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204748
Address: 1516 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, November 16, 2021

Corrective Action Required:

1	Misc	-Final grade and sod -guard rail at front stoop where more than 30" , 36" out -spark ring for outlet above fireplace -missing spindle at stairwell guard rail -secure A/c whip within 12" of disconnect -splash blocks extending 36" from foundation -check water meter at final grade and sod -sidewalk inspection need be completed
---	------	--

Comments: