

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214591
Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	Ronald Paynter	Failed	Tuesday, November 16, 2021

Corrective Action Required:

1	Misc	Doesn't have 10 feet of copper pipe out of the meter pit. Told contractor that he needs 10 feet and that it can't be spliced together. RP 11-16-21
---	------	--

Comments: