

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20211246

Address: 1010 NW PRYOR RD, LEES SUMMIT, MO 640811000 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Abandonment</b>	Ronald Paynter	Failed	Tuesday, November 16, 2021

Corrective Action Required:

1	Misc	Earl from ESS removed existing manhole and sanitary pipe to correct abandonment location. Plans called for a cap, but explained that our spec calls for a plug. They plan on correcting this issue tomorrow. RP 11-16-21
---	------	--

**Comments:**