

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20214416  
Address: 540 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Site Visit</b>	John Jackson	Partial	Monday, October 11, 2021

Informational:

1	Misc	10-11-21 Monday Site Visit grading and excavation was contained by erosion control fencing. 11/16/21 Tuesday (ESS) Contractor was not on site. Water tap 6" main that ties in to the Backflow preventer. Contractor did remove back hoe equipment from site. The tie-in portion of the main needs to be chlorinated and pressure tested .
---	------	--

**Comments:**