

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204198
Address: 125 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, November 17, 2021

Corrective Action Required:

1	Misc	-Garage portal ok -Rear patio roof ok to cover
---	------	---

Corrective Action Required:

2	Misc	-security blocking at front door -Dbl top plates require 24" offset between plate breaks, -2nd floor East bedroom west corner nail off
---	------	--

Comments: