

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20214153

Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081
2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary - Material Verification	Ronald Paynter	Partial	Wednesday, November 17, 2021

Informational:

1 Misc Sanitary materials onsite include: 6", 8", 10" SDR26 pipe, wye fittings, bends and max adapters for the wye connections. Still waiting on all manhole components(barrels, cones, adjustment risers, rings and lids). 11/9 ES.

Informational:

2 Misc Sanitary Manhole base, barrel, and cone sections were delivered, manufactured by Barbour with correct steps and A-Locks. Still waiting for castings and lids. 11/17 ES

Comments: