

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211323  
Address: 3130 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Wednesday, November 17, 2021

Corrective Action Required:

1	Misc	-seal all top plate penetrations -1st floor bath, 2nd floor north bed closet -seal all penetrations through air returns, studs and floor joist cavities -Dbl top plate requires min 24" offset between plate breaks - see master bed 2nd floor west exterior wall -Protect NM (romex) within 6' of attic entrance (see above hall)
---	------	--

**Comments:**