

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20214277  
Address: 940 NW PRYOR RD, Unit:G, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Michael Harkins	Failed	Wednesday, November 17, 2021

Corrective Action Required:	
1      Miscellaneous	PRESSURE STEADY ON DWV
Correction	NO ELECTRICAL STARTED
	PROVIDE MIDPOINT STRAP VERTICAL DWV 2" & SMALLER
	FIRE CAULK DWV FLOOR PENETRATIONS

**Comments:**