

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20213070
Address: 4817 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Mark Harding	Failed - Stop Work	Wednesday, November 17, 2021

Corrective Action Required

1	DCM6 ESC INSP DENIED STREET CLEAN UP	REQUESTED INSPECTION(S) DENIED. STREET CLEAN UP REQUIRED IMMEDIATELY, AND SHALL BE COMPLETED PRIOR TO REQUESTED INSPECTION(S) BEING PERFORMED.
---	---	--

****THE LOT GRADER REGRADED THIS LOT AND THE ADJACENT
LOT. DURING GRADING, THE SILT FENCE ALONG THE STREET WAS
TORN DOWN AND MUD TRACKED ONTO THE STREET. THE
BUILDER BLAMED THE ADJACENT LOT BUILDER, BUT THE
ADJACENT LOT HAS NOT BEEN DUG FOR THE FOOTING YET.**

Corrective Action Required

2	DCM1 ESC REQUIRED NO FURTHER INSP	stop construction issued until issue is resolved.DANDBUILDING@GMAIL.COM
---	--------------------------------------	--

**EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL
BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN
COMPLIANCE.**

**DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER
INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.**

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Comments: