

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210625
Address: 2110 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Wednesday, November 17, 2021

Corrective Action Required:

2	Miscellaneous Correction	Provide LUS24 hanger girder truss B1 garage per truss plans (east wall near front porch) Provide 4 stud pack at girder truss bearing points throughput per roof plan (west garage wall) Nail studs at intersecting wall corners per plan (bed # 2 near front porch) Provide CS-PF nailing pattern SGD & dining room windows 3" GRID PATTERN (2018 IRC FIGURE R602.10.6.4)
---	--------------------------	--

Comments: