CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214591

Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Water Service Inspection Ronald Paynter Passed Wednesday,

November 17, 2021

Corrective Action Required:

1 Misc Doesn't have 10 feet of copper pipe out of the meter pit. Told contractor that

he needs 10 feet and that it can't be spliced together. RP 11-16-21

Informational:

2 Misc Contractor installed new copper pipe over 10 feet long out of the meter. We

went to Water Dept and got them a new meter well, since the old one was

dug up and in bad shape. RP 11-17-21

Comments: