

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211738
Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Partial	Wednesday, November 17, 2021

Informational:	
1 Misc	- OSB PARAPET WALLS ROOF SIDE, DENSROCK EXTERIOR WALLS -
Corrective Action Required:	
2 Miscellaneous	: BAR AREA NOT READY FOR INSPECTION 11/17/21:
Correction	OK TO COVER WALLS EXCEPT BAR

Comments: