

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215563
Address: 1620 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Patrick Schonfeldt	Failed	Wednesday, November 17, 2021

Corrective Action Required:

1	Misc	FOOTING APPROVED, NO ADDITIONAL INSPECTIONS TO BE PERFORMED UNTIL SWALE AT REAR OF LOT HAS BEEN RESTORED TO DESIGN APPROVED ON PLOT PLAN AND SWALE PROTECTED BY PROPER EROSION CONTROL. SWALE HAS BEEN ALTERED DURING EXCAVATION FOR FOOTING/FOUNDATION, SPOILS PILE LOCATED IN SWALE AND TRACKS FROM MACHINERY MOVING THROUGH SWALE
---	------	--

Comments: