



Alpha Omega Geotech, Inc
1701 State Avenue
Kansas City, KS 66102
Phone: 913-371-0000

Reinforcing Steel Inspection Report

Client:

LSPH Investors, LLC
7939 Floyd Street
Overland Park, KS 66204

Project:

21-390F
Chipotle Lee's Summit
1130 SE Oldham Pkwy
Lee's Summit, MO

Activity Date: 11/15/2021**Technician:** Lipp, Carmen**Time In:** 11:00**Time Out:** 14:00**Temperature (F):** 62**Weather:** Partly Cloudy

GENERAL OBSERVATIONS

Location of Rebar Inspected: South dumpster enclosure footing and perimeter of interior building for hold downs**Plans Used:** Structural drawings**Drawing No.:** Sp102**Rebar Size: Per Approved Drawing:** Yes**Spacing Within Tolerance:** Yes**Supporting System (Specify):** concrete brick

FIELD OBSERVATIONS

Straight: Yes**Clean:** Yes**Tied:** Yes**Clearance Per Specs:** Yes**Rebar Displaced During Placement:** No**Drill & Epoxy Details (If Applicable):** Yes**Product:** Hit-hy 200 R**Embedment Depth (in):** 18**Are There Non-Compliance Items:** No