

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210754
Address: 337 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, November 18, 2021

Corrective Action Required:

- | | | |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none">- Erosion control, swaddles in front and gravel in street- obtain a sprinkler permit and back flow certification- Final grading and sod- 36" splash blocks or finish pop ups- master bath, light 4' from tub. Minimum 8'-water hammer preventer for dishwasher- lock and secondary lock for sliding door-vent against expansion tank on water heater- M1502.4.5.1 Dryer vent length max 35' you have 21' straight with 4 x 90s =41' |
|---|--------------------------|---|

Comments: