

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214591
Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Michael Harkins	Failed	Thursday, November 18, 2021

Informational:	
2 Misc	11/15/21 - INSPECTED TRASH ENCLOSURE FOOTING
Corrective Action Required:	
3 Miscellaneous Correction	PROVIDE APPROVED CLAMP AT UFER (CONCRETE ENCASED ELECTRODE) BRASS ON BRASS : UFER LOCATED SOUTH OF REAR DOOR :

Comments: