

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20213306  
Address: 4805 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:            | Inspector:   | Outcome: | Date:                     |
|------------------------|--------------|----------|---------------------------|
| <b>Erosion Control</b> | Khanh Nguyen | Failed   | Friday, November 19, 2021 |

Corrective Action Required:

|   |   |   |
|---|---|---|
| 1 | DCM1 ESC<br>REQUIRED NO<br>FURTHER INSP | EROSION CONTROL REQUIRED ALONG THE STREET. THE STREET SHALL BE<br>CLEANED OF SOIL AND DEBRIS. MIN 3/4" GRAVEL SHALL BE PROVIDE AT LOT<br>ENTRANCE |
|---|---|---|

FAILURE TO COMPLY WITHIN 2 DAYS WILL RESULT IN AN ISSUANCE OF  
STOP-WORK

NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS  
INSTALLED AND IN COMPLIANCE.

**Comments:**