

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213688  
Address: 4708 NE FREEHOLD DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Friday, November 19, 2021

Corrective Action Required:

1 Misc

**\*\*INSTALL EROSION CONTROL ALONG THE STREET. STREET SHALL BE CLEANED OF DIRT AND GRAVEL**

- Fasten front exterior wall sheathing and siding to sill plates @6" oc
- Nail garage corner studs per code
- Support bottom of hip rafter at rear corner of master bedroom
- Fill in gap behind basement walkout door hinges with solid wood

**\*\*OK TO INSULATE**

**Comments:**